

**STATE OF ILLINOIS
ILLINOIS COMMERCE COMMISSION**

ILLINOIS COMMERCE COMMISSION)	
On its Own Motion)	
)	
vs)	
)	
AMEREN ILLINOIS COMPANY)	
d/b/a Ameren Illinois)	Docket No. 20-0389
)	
Investigation under Section 16-107.6(e))	
of the Public Utilities Act into an annual)	
process and formula for the calculation)	
of distributed generation rebates)	

REBUTTAL TESTIMONY OF
CURT VOLKMANN

ON BEHALF OF

THE ENVIRONMENTAL LAW AND POLICY CENTER
VOTE SOLAR
AND
NATURAL RESOURCES DEFENSE COUNCIL

February 5, 2021

TABLE OF CONTENTS

I. INTRODUCTION AND WITNESS QUALIFICATIONS 1

II. PURPOSE OF TESTIMONY AND SUMMARY OF RECOMMENDATIONS 3

III. THE COMPANY’S PROPOSED FRAMEWORK IS OVERLY COMPLEX AND OPAQUE 5

 1. *AIC has not determined its proposed short-term Distribution Capacity Values..... 7*

 2. *AIC has not determined its proposed Voltage Support Value 14*

 3. *AIC has not determined its proposed Subtransmission Contingency Planning Value 15*

 4. *AIC has not calculated the Line Loss Reduction Value..... 16*

 5. *AIC has not determined its proposed total rebate values..... 17*

 6. *AIC will not seek future Commission approval of the unknown rebate values 19*

IV. AIC’S PROPOSED FRAMEWORK IS FLAWED..... 21

V. AIC’S PROPOSED FRAMEWORK IS TOO NARROWLY FOCUSED..... 26

 1. *The Framework should consider the impact of other DER, particularly solar-plus-storage, on the value of DG..... 27*

 2. *DG rebates should include additional long-term, system-wide DER value 33*

VI. SUMMARY OF RECOMMENDATIONS..... 35

1 **I. INTRODUCTION AND WITNESS QUALIFICATIONS**

2 **Q. Please state your name and business address.**

3 A. My name is Curt Volkman. My business address is 132 Lake Vista Circle, Fontana,
4 Wisconsin, 53125.

5 **Q. On whose behalf are you testifying in this proceeding?**

6 A. I am testifying on behalf of the Environmental Law & Policy Center, Vote Solar, and the
7 Natural Resources Defense Council (collectively “Joint NGOs” or “JNGO”).

8 **Q. By whom are you employed and in what capacity?**

9 A. I am President and founder of New Energy Advisors, LLC, an independent consulting firm.
10 I work with clients in a variety of regulatory proceedings related to distribution system
11 planning, distributed energy resources, and grid modernization.

12 **Q. Please summarize your education and professional experience.**

13 A. I have a BS in Electrical Engineering from the University of Illinois with a concentration
14 in Electrical Power Systems. I also have an MBA from the University of California at
15 Berkeley with a concentration in Finance. I have 36 years of experience in the utilities
16 industry, primarily in electric transmission and distribution. My work experience includes
17 nine years at Pacific Gas & Electric in various transmission and distribution engineering
18 roles and eighteen years at Accenture with several positions including Executive Director
19 in the North American Utilities practice. Since 2015, I have worked independently and
20 supported clients in distribution-related regulatory proceedings around the country. JNGO
21 Exhibit 3.01 provides a statement of my qualifications and experience.

22 **Q. Have you previously testified before the Illinois Commerce Commission?**

23 A. Yes. I testified before the ICC in:

- 24 • The Ameren IL proceeding for approval of its Energy Efficiency and Demand
25 Response Plan in Docket No. 13-0498.
- 26 • The Commonwealth Edison proceeding for approval of its Energy Efficiency and
27 Demand Response Plan in Docket No. 13-0495.
- 28 • Its investigation into Commonwealth Edison's cost of service in Docket No. 14-
29 0384.
- 30 • The Ameren IL proceeding for approval of its customer generation rebate and
31 customer generation charge in Docket No. 18-0537.
- 32 • The Commonwealth Edison proceeding for approval of its customer generation
33 rebate and customer generation charge in Docket No. 18-0753.

34 **Q. Have you previously testified before other regulatory commissions?**

35 A. Yes. In the past five years, I have testified and commented before regulatory commissions
36 in Arizona, Arkansas, California, Iowa, Michigan, Minnesota, New York, Ohio, Utah, and
37 Virginia. JNGO Exhibit 3.02 provides a summary of my prior testimony and contributions
38 to comments.

39 **Q. Are you providing any exhibits with your testimony?**

40 A. Yes. I am sponsoring the following exhibits:

- 41 • JNGO Exhibit 3.01: Curt Volkmann's Statement of Qualifications and Experience
- 42 • JNGO Exhibit 3.02: Prior Testimony and Contributions to Comments by Curt
43 Volkmann

- 44 • JNGO Exhibit 3.03: Compiled responses to discovery requests

45 **II. PURPOSE OF TESTIMONY AND SUMMARY OF RECOMMENDATIONS**

46 **Q. What is the purpose of your rebuttal testimony?**

47 A. My rebuttal testimony summarizes my assessment of the Distributed Generation (“DG”) Rebate Valuation Framework (“Framework”) proposed by the Ameren Illinois Company (“AIC”, “Ameren”, or “Company”) and described in the Company’s direct testimony.

50 **Q. What did you review in preparing your rebuttal testimony and forming your conclusions and recommendations?**

52 A. I reviewed all parties’ direct testimony and exhibits and the Company’s responses to discovery requests issued by all parties.

54 **Q. Please summarize your conclusions regarding AIC’s proposed DG Rebate Valuation Framework.**

56 A. I conclude that the proposed Framework is overly complex and opaque, flawed, and too narrowly focused. My criticisms of the Framework include the following:

- 58 • AIC has not sufficiently calculated values using the proposed Framework to determine its reasonableness. No party in this proceeding, including the Company, has any idea what the resulting values would be for the vast majority of AIC’s customers.
- 62 • AIC does not intend to fully calculate the values until the Commission approves the methodology.
- 64 • AIC’s proposed approach for determining short-term locational capacity deferral value is flawed.

- 66 • The Framework fails to account for the significant impacts of solar paired with
67 storage on the value of solar DG systems.
- 68 • The Framework fails to reflect the full value of distributed energy resources
69 (“DER”) to AIC’s distribution system. At best, and with the changes I recommend
70 in my testimony, the Framework offers a potential methodology for calculating
71 short-term locational values that could be adders to a more comprehensive base
72 rebate.

73 **Q. Please provide a brief summary of your recommendations.**

74 A. I recommend that the Commission:

- 75 1) Determine that AIC’s proposed Framework is incomplete and produces only short-
76 term locational value adders, not rebate values reflecting the full value of DER to the
77 distribution system.
- 78 2) Require AIC to modify its proposed Framework for determining short-term
79 locational value adders to:
- 80 a. Include the impact on the value of DG when it is paired with storage.
- 81 b. Build flexibility into the Framework that allows AIC to reflect, in rebate values,
82 the impact of other load-modifying DER on the value of solar DG paired with
83 storage, as those impacts are better understood and quantified in the future.
- 84 c. Incorporate the revised DG Value Matrix shown in Figure 5 of my rebuttal
85 testimony.
- 86 3) Require AIC to calculate and publish all short-term locational value adders resulting
87 from its proposed Framework for all of AIC’s customers, prior to Commission
88 approval of the methodology.

- 89 4) Require AIC to establish a transparent process for ongoing Commission, Staff, and
90 stakeholder review and Commission approval of the data and calculations supporting
91 the Framework’s short-term locational value adders and Non-standard Rebates¹. This
92 should preferably be part of the robust and transparent Integrated Distribution
93 Planning process recommended by JNGO witnesses Kenworthy² and Sandoval³.
- 94 5) Order AIC to begin working with Staff, stakeholders, and an independent third party
95 facilitator, to conduct a comprehensive and transparent Value of DER analysis to
96 determine the full DER base rebate value.
- 97 6) To the extent the Company has not completed the Value of DER analysis before DG
98 penetration reaches 5% in AIC’s service territory, order AIC to establish an initial
99 base rebate value equivalent to the value of delivery-service netting, as recommended
100 and further detailed in JNGO witness Kenworthy’s testimony.⁴

101 **III. THE COMPANY’S PROPOSED FRAMEWORK IS OVERLY COMPLEX AND**
102 **OPAQUE**

103 **Q. What is your understanding of how AIC approached the development of its proposed**
104 **Framework?**

105 A. I understand that AIC began to assemble a Framework team in 2017 and has worked on
106 the methodology for the last 2-3 years. In response to a data request, AIC provided several

¹ The Company states that, for DG installations that utilize non-standard smart inverter settings, AIC may adjust the available rebate by mutual agreement of the Customer and the Company (“Non-standard Rebates”). I discuss these Non-standard Rebates at p. 20 of my testimony.

² JNGO Exhibit 1.0 lines 34:14-36:13

³ JNGO Exhibit 2.0 lines 31:17-34:3

⁴ JNGO Exhibit 1.0 lines 38:16-39:5

107 internal team documents from AIC's early work.⁵ One of the guidelines from the 2018 AIC
108 team kickoff was, "Do not reinvent the wheel – Leverage what others have already
109 accomplished in this field".⁶

110 **Q. Has AIC adhered to this guideline?**

111 A. No. In my opinion, AIC's proposed Framework does "reinvent the wheel". It is unlike
112 anything I have seen before.

113 **Q. What is the scope of AIC's proposed Framework?**

114 A. AIC's proposed Framework is focused only on short-term⁷ value components in locations
115 with identified system needs. It is also very granular, as AIC proposes to analyze 1.45
116 million distribution system components each year⁸ and update the \$/kW rebate values
117 annually for each of its 371,461 distribution transformers.⁹ As I will describe later, the
118 Framework fails to address the full value of DG and other DER to the Company's
119 distribution system. I agree with Joint Solar Parties witness Rábago who states, "The
120 Company's work is a good starting point for calibrating locational adders to the DG rebate,
121 even if it fails to address the full value of the DG to the distribution system at the location
122 that it is interconnected."¹⁰

⁵ JNGO Exhibit 3.03, AIC response to ELPC-VS 5.01(a).

⁶ JNGO Exhibit 3.03, AIC response to ELPC-VS 5.01, Attach 4_DER Valuation Team Kick-off.pdf, pp. 7-9.

⁷ The Framework only accounts for the locational impact of DG over AIC's 5-year distribution planning horizon while ignoring any impacts beyond that 5-year horizon and over the remainder of the life of the DG assets.

⁸ JNGO Exhibit 3.03, AIC response to ELPC-VS 4.11.

⁹ JNGO Exhibit 3.03 AIC response to ELPC-VS 1.01(i).

¹⁰ JSP Exhibit 1.0, lines 543-545.

123 **Q. What are the short-term locational value adder components of AIC's proposed**
124 **Framework?**

125 A. AIC has identified four short-term locational value adder components in its proposed
126 Framework, specifically:

- 127 • Distribution capacity value;
- 128 • Voltage support value;
- 129 • Subtransmission contingency planning value, and;
- 130 • Loss reduction value.

131 I will address AIC's proposed approach to calculating each short-term locational value
132 adder component below.

133 **1. AIC has not determined its proposed short-term distribution capacity values**

134 **Q. Please explain distribution capacity value and your understanding of AIC's proposed**
135 **methodology for calculating this component.**

136 A. Distribution capacity value reflects the ability of DG to reduce peak loads and defer the
137 replacement of distribution assets that might otherwise be overloaded. My understanding
138 of AIC's proposed methodology for this component is the following:

- 139 1. AIC, through its annual planning process, will collect distribution system
140 information, load forecasts, as well as current and future committed DG information.
141 AIC will update its distribution system models to reflect the current system status.
142 AIC will prepare the best available (real-time historic or modeled data) load data
143 and DG profiles.
- 144 2. Using the information and data prepared in Step 1, AIC will utilize its existing power
145 system analysis tool to determine potential asset-specific planning criteria violations

- 146 (i.e., where the loading or voltage is projected to be outside of the acceptable range
147 within the forecast period).
- 148 3. For each distribution system asset with a potential planning criteria violation, AIC
149 will:
- 150 i. Determine the normal and emergency ratings.
 - 151 ii. Determine the 5-year forecasted load profile for the asset in 8,760 hourly
152 intervals each year, scaled up for both estimated load growth and temperature
153 correction, and determine the asset's "Before DG" peak load each forecast
154 year.
 - 155 iii. Determine the expected generator output for 1 kW of DG from PVWatts,¹¹
156 multiply the expected unit generator output profile by a factor of 100 to
157 represent an addition of 100 kW, then subtract the result from the forecasted
158 8,760 load profile values.
 - 159 iv. Repeat this calculation in increments of 100 kW from 200 kW to 10,000 kW.
 - 160 v. Determine the new highest measured "After DG" peak load value for each 100
161 kW incremental addition of DG.
 - 162 vi. From the "After DG" incremental peak load values, determine the magnitude
163 of the change in measured peak load between each incremental addition of DG.
164 When the change in measured peak load drops below 10 kW for a 100 kW
165 addition due to diminishing returns, record both the new measured "After DG"
166 peak load value and the amount of DG added for the previous incremental
167 addition.
 - 168 vii. Determine the present year estimated upgrade/replacement cost of the asset,
169 and translate the upgrade/replacement cost into the appropriate year future cost
170 using a 2% inflation rate.
 - 171 viii. Determine the Value Multiplier and Rebate Value by applying the upgrade
172 cost, normal rating, emergency rating, "Before DG" peak load value, and
173 "After DG" peak load value to a "DG Value Matrix".

¹¹ PVWatts is a tool developed by the National Renewable Energy Lab for estimating the production of solar PV systems. See <https://pvwatts.nrel.gov>.

- 174 ix. Calculate the Eligible Facility Value per kW in the forecast year by dividing
175 the Rebate Value by the amount of DG required to reach the point where an
176 addition of 100 kW reduces the magnitude of the measured peak load by less
177 than 10 kW.
- 178 x. Convert the Eligible Facility Value per kW to a present value using the
179 Company's weighted average cost of capital, which is currently 6.393%.
- 180 xi. Apply the calculated Eligible Facility Value per kW to each downstream
181 distribution transformer.
- 182 4. Once AIC has calculated all Eligible Facility Value per kW values, including other
183 distribution capacity contributions, voltage support value, and subtransmission
184 value elements that apply to each customer, it will sum them and round up to the
185 nearest \$25/kW increment to determine the Rebate Amount to be paid to the
186 customer.¹²

187 **Q. In step 3.vi above, you mention diminishing returns. What is this?**

188 A. AIC assumes that as more solar DG is installed on a circuit, after a certain point, the peak
189 load-reducing impact of each incremental addition of DG is less than previous installations.

190 As the Company explains:

191 "The concept of diminishing returns ... is directly related to time-varying
192 differences between the energy output of the DG and load profile of the
193 circuit. In the example of solar, the energy output is restricted to a specific
194 set of hours based on the availability of sunlight ... When there is very little
195 nameplate solar production capacity installed on a feeder, there is a
196 significantly higher likelihood of overlap between load on the circuit and
197 the ability of solar DG to reduce that load. As more solar is added on the
198 same feeder, the measured loading on the feeder decreases only during the
199 hours the solar is producing energy. Over time, this shifts the timing of the
200 measured peak load to be later in the evening or earlier in the morning,
201 when load is still relatively high but there is less sunlight available to
202 stimulate solar production. Once this occurs, the impact on the measured
203 peak load of each incremental addition of solar is much lower than earlier
204 installations, and eventually reaches a point where the DG does not have a

¹² Ameren Exhibit 2.1.

205 significant impact on the measured peak load value. After that point is
206 reached, additional DG does not provide any significant capacity value.”¹³

207 **Q. How has AIC factored diminishing returns into its Framework?**

208 A. Diminishing returns is a foundational concept in AIC’s proposed Framework. As AIC
209 explains, “The idea of diminishing returns is used as a means of determining a specific cut-
210 off point beyond which the value provided by an incremental addition of DG does not
211 significantly contribute to the overall value available at a specific asset. This cut-off point
212 is used to determine both the magnitude of impact of the DG to the peak load and the
213 denominator of the ‘\$/kW’ value calculation. Within the framework, a 10% criteria was
214 selected for this cut-off point, which is defined by the point at which an incremental
215 addition of 100kW of generation results in less than 10kW of peak load reduction on a
216 particular component.”¹⁴

217 **Q. In step 3.viii above, you mention a DG Value Matrix. What is this?**


218 A. The DG Value Matrix is a method that Ameren proposes for determining the “value
219 multiplier” that it would apply to upgrade costs in order to determine rebate values. The
220 concept underlying Ameren’s DG Value Matrix is that DG value must be prorated such
221 that compensation corresponds with the degree of capacity relief the DG provides.

222 The Company explains, “Overload reduction value calculations (for distribution capacity
223 deferral) will be based on the actual average upgrade cost of the asset, the severity of the
224 overload condition, and the degree to which the DG reduces the overload condition. The

¹³ Ameren Exhibit 2.0, lines 250-264.

¹⁴ Ameren Exhibit 2.0, lines 278-284.

225 value available is linearly prorated, with no value at the normal rating; and maximum value,
 226 totaling the cost of replacing the asset, available at the emergency rating.”¹⁵ Figure 1 below
 227 illustrates this concept.



228
 229 **Figure 1 – AIC’s Proposed DG Value Proration¹⁶**

230 AIC further explains, “The value of a DG installation on an overloaded facility is the
 231 difference in loading due to the DG divided by the value proration factor (from the DG
 232 Value Matrix in Figure 2 below), then multiplied by the cost of upgrading the affected
 233 asset.”¹⁷

¹⁵ Ameren Exhibit 1.2, p. 6.

¹⁶ Ameren Exhibit 1.2, p. 7.

¹⁷ *Id.*

		Under Normal	Over Normal	Over Emergency	Value Description	Value Multiplier
Case 1	Before DG	X			No Overload	No Value
	After DG	X				
Case 2	Before DG		X		Eliminated Overload	$(\text{Before Load} - \text{Normal Rate}) / (\text{Emergency Rate} - \text{Normal Rate})$
	After DG	X				
Case 3	Before DG			X	Eliminated Emergency	Full Upgrade Value
	After DG	X				
Case 4	Before DG		X		Reduced Overload	$(\text{Before Load} - \text{After Load}) / (\text{Emergency Rate} - \text{Normal Rate})$
	After DG		X			
Case 5	Before DG			X	Reduced Emergency	$1 - (\text{After Load} - \text{Normal Rate}) / (\text{Emergency Rate} - \text{Normal Rate})$
	After DG		X			
Case 6	Before DG			X	Over Emergency	No Value
	After DG			X		
Rebate Value = Upgrade Cost * Value Multiplier						

234

235

Figure 2 – AIC’s Proposed DG Value Matrix¹⁸

236 **Q. What value or range of values can customers expect for the distribution capacity**
 237 **component of the rebate?**

238 A. I don’t know and neither does AIC. The Company provided only one example of the fully
 239 operationalized methodology for distribution capacity, including the diminishing returns
 240 and present value calculations, for a substation transformer overload (“Operationalized
 241 Example”). As shown in Figure 3 below, this Operationalized Example results in a rebate
 242 value of \$25.99/kW, which AIC would round up to \$50/kW.

¹⁸ *Id.*

Transformer Overload DER Value Example	2022	2023	2024	2025
TC Peak Load	9.02	9.12	9.222	9.32
Normal Rating (MVA)	9	9	9	9
Emergency Rating (MVA)	10.7	10.7	10.7	10.7
10% DR Nameplate PV MW	4.2	4.3	4.3	4.4
10% DR Peak Load Reduction (MW)	0.941	0.943	0.963	0.979
Replacement Cost	\$780,300	\$795,906	\$811,824	\$828,061
Available Rebate Value (\$)	\$9,180.00	\$56,181.60	\$106,014.68	\$155,870.23
Rebate Value (\$/kW)	\$2.19	\$13.07	\$24.65	\$35.43
Present Year Rebate Value (\$/kW)	\$1.93	\$10.85	\$19.24	\$25.99

Figure 3 – Operationalized Example¹⁹

However, AIC also states that the example calculation is “intended to provide clarity and insight into the actual computations in the framework, and do(es) not necessarily represent expected general rebate values. Ameren Illinois will complete the proposed analysis for its entire distribution system once the methodology is approved.”²⁰

Q. What do you conclude?

A. I conclude the AIC’s proposed methodology for calculating distribution capacity value is overly complicated and opaque. AIC has not provided visibility into key inputs for the calculations (i.e., load forecasts, equipment loading and ratings, equipment upgrade/replacement costs). More importantly, no party in this proceeding, including the

¹⁹ Ameren Exhibit 2.1, p. 1.

²⁰ Ameren Exhibit 1.2, p. 11.

254 Company, has any idea what the resulting distribution capacity values would be for AIC's
255 customers.

256 **2. AIC has not determined its proposed voltage support values**

257 **Q. Please explain the voltage support value and AIC's proposed methodology for**
258 **calculating this component.**

259 A. Through its annual planning process, the Company identifies locations on its distribution
260 system that require additional voltage support, reactive-power capacity support, or other
261 power factor correction through capacitor bank placement.²¹ AIC proposes to include a
262 voltage support value component for DG with smart inverters installed in these locations.
263 Specifically, AIC proposes a flat \$/kW adder for all locations with modeled voltage below
264 117 volts over the 5-year planning horizon.²²

265 **Q. What value or range of values can customers expect for the voltage support adder?**

266 A. I don't know and neither does AIC. The Company's illustrative calculation results in a
267 value of \$23.04/kW for all locations with modeled voltage below 117 volts, and \$0/kW (no
268 adder) for all other locations.²³ However, the Company also states, "A specific \$/kW value
269 for the voltage adder has not yet been determined for the present year or any future years."²⁴

²¹ JNGO Exhibit 3.03, AIC response to ELPC-VS 1.20.

²² Ameren Exhibit 2.3.

²³ Ameren Exhibit 2.3.

²⁴ JNGO Exhibit 3.03, AIC response to ELPC-VS 4.10.

270 **Q. What percentage of customer locations on AIC’s circuits does the Company expect to**
271 **receive a voltage support adder?**

272 A. I don’t know and neither does the Company, as it has not conducted sufficient analysis to
273 answer this question.

274 **3. AIC has not determined its proposed subtransmission contingency planning**
275 **Value**

276 **Q. Please explain the subtransmission contingency planning value and AIC’s proposed**
277 **methodology for calculating this component.**

278 A AIC identifies opportunities for capacity deferral on its subtransmission system²⁵ by
279 modeling the system under a variety of loading conditions and contingency configurations.
280 While the Company acknowledges that distributed generation has subtransmission
281 contingency planning value, the Company explains, “Currently, there are no commercial
282 modeling tools available that can model time-series load profiles and contingency
283 switching scenarios simultaneously. This limitation, when considered alongside the
284 relative complexity of the necessary process, makes specific calculations [of
285 subtransmission contingency planning values] impractical.”²⁶ Instead, Ameren proposes to
286 calculate a flat value adder to be applied to all customer locations that impact identified
287 subtransmission contingency planning criteria violations.²⁷

²⁵ Within AIC, the subtransmission system includes facilities operating at 34 kV or 69 kV.

²⁶ Ameren Exhibit 1.2, p. 10.

²⁷ Ameren Exhibit 2.2.

288 **Q. What values or range of values can customers expect for the subtransmission**
289 **contingency planning adder?**

290 A. I don't know and neither does AIC. In response to a data request, the Company stated,
291 "Ameren Illinois has not performed sufficient calculations at this time to provide an
292 accurate flat value adder expectation."²⁸

293 **Q. What percentage of customer locations on AIC's circuits does the Company expect to**
294 **receive a subtransmission contingency planning adder?**

295 A. I don't know and neither does AIC, as it has not conducted sufficient analysis to determine
296 the percentage.

297 **4. AIC has not calculated the Line Loss Reduction Value**

298 **Q. Please explain the line loss reduction value and AIC's proposed methodology for**
299 **calculating this component.**

300 A. The energy produced by DG to serve local load reduces the energy that flows along the
301 subtransmission and distribution system, thus reducing line losses. AIC explains, "Since
302 the impact of losses on distribution capacity are highly locational, it is impractical to
303 calculate a specific magnitude for this value without modeling each application
304 individually. Simplifying assumptions must be made in order to ensure this value is
305 included in the calculations in a way that is practical."²⁹ AIC asserts that the line loss
306 reduction value is captured indirectly as part of the round-up approach instead of through
307 direct calculation.³⁰

²⁸ JNGO Exhibit 3.03, AIC response to ELPC-VS 5.16.

²⁹ Ameren Exhibit 1.2, p. 9.

³⁰ Ameren Exhibit 2.0, lines 426-428.

308 **Q. What are the implications of this approach for AIC's customers?**

309 A. Accounting for the value of reduced line losses by "rounding up" to the nearest \$25/kW
310 increment means that, for example, a DG system providing \$99/kW of capacity,
311 contingency, and voltage support value to the grid would effectively receive \$1/kW for line
312 loss reduction value. A similar DG system providing \$101/kW of capacity, contingency,
313 and voltage support value to the grid would effectively receive \$24/kW for line loss
314 reduction value. In both cases, compensation for line loss reduction value would not
315 necessarily have any relationship with the actual loss reductions that the particular DG
316 system provides.

317 **5. AIC has not determined its proposed total rebate values**

318 **Q. What is a reasonable estimate of what customers can expect for the total short-term**
319 **locational value adders resulting from the proposed Framework?**

320 A. Once again, I don't know and neither does AIC. As I previously explained, the Company
321 has provided only one full example, the Operationalized Example, resulting in \$50/kW for
322 distribution capacity. However, this example does not include voltage support or
323 subtransmission contingency planning flat value adders.³¹ It also assumes that line loss
324 reduction value is captured through the round-up approach.

325 **Q. Has the Company provided any other estimates of what the total rebate values might**
326 **be for customers?**

327 A. In response to a Staff data request, AIC provided rebate values for 1,856 distribution
328 service transformers serving a total of 6,016 customer locations, and the results are shown

³¹ Ameren Exhibit 2.1.

329 in Figure 4 below. These calculations do not include any potential subtransmission
 330 contingency planning adder.

Value Block	# of Customers	% of Customers
\$0/kW	2,490	42%
\$25/kW	174	3%
\$50/kW	2,777	47%
\$75/kW	264	4%
\$100/kW	215	4%
\$125/kW and above	0	0%

331

332

Figure 4 – Estimated Rebate Values³²

333 The Company states, “Ameren Illinois' calculations to date have primarily been focused on
 334 specific equipment or locations where forecasted planning criteria violations have been
 335 identified, and are not representative of the distribution system as a whole.”³³ The
 336 Company also states that it does not intend to calculate rebate values for all distribution
 337 service transformers on its distribution system prior to the expected date for the
 338 Commission’s final Order.³⁴

339 **Q. Why hasn’t AIC calculated rebate values for all distribution service transformers
 340 across its distribution system?**

341 A. In response to a data request, the Company stated “Ameren Illinois considers it imprudent
 342 to dedicate resources, time and effort to calculate rebate values for all distribution service
 343 transformers on its distribution system without a Commission order approving Ameren
 344 Illinois' methodology. Ameren Illinois conducted a sufficient number of calculations to

³² JNGO Exhibit 3.03, derived from AIC response to POL 1.17S.

³³ JNGO Exhibit 3.03, AIC response to POL 1.17S.

³⁴ JNGO Exhibit 3.03, AIC response to ELPC-VS 3.06(a).

345 demonstrate proof of concept, and is prepared to perform the full-scale calculation of DG
346 values should the Commission approve its methodology.”³⁵

347 **6. AIC will not seek future Commission approval of the unknown rebate values**

348 **Q. If the Commission approves the Framework and AIC calculates rebate values across**
349 **its distribution system, does the Company intend to seek Commission approval of**
350 **these rebate values?**

351 A. No. The Company states, “AIC expects the Commission to approve the methodology for
352 calculating actual rebate values, not the rebate values themselves.”³⁶ The Company also
353 states, “AIC understands the Commission will be reviewing a methodology and series of
354 calculations in this proceeding which will result in rebate values in the initial year and
355 subsequent years. Therefore, AIC believes the Commission will be approving the rebate
356 values by virtue of approving a methodology and standardized calculations.”³⁷

357 **Q. Does AIC intend to share its future DG rebate value calculations with the**
358 **Commission, Staff and stakeholders?**

359 A. Only if asked. In response to a data request, AIC states that it does not intend to file,
360 publish, disclose, or otherwise make any “supporting data from the value calculation
361 process” available to the Commission or Staff unless requested by the Commission or
362 Staff.³⁸

³⁵ JNGO Exhibit 3.03, AIC response to ELPC-VS 4.18.

³⁶ JNGO Exhibit 3.03, AIC response to ELPC-VS 3.06(d).

³⁷ JNGO Exhibit 3.03, AIC response to ELPC-VS 4.20.

³⁸ JNGO Exhibit 3.03, AIC response to ELPC-VS 5.04.

363 **Q. Is the Company proposing exceptions to the DG rebate values?**

364 A. Yes. AIC explains, “The ability for customers to utilize non-standard (smart inverter)
365 settings would, in some cases, allow for a customer to interconnect their proposed DG
366 facility without triggering the need for grid upgrades that would otherwise be necessary if
367 default settings were utilized instead. This results in reduced interconnection costs for the
368 customer.”³⁹ The Company further states that, for DG installations that utilize non-standard
369 smart inverter settings, AIC may adjust the available rebate by mutual agreement of the
370 Customer and the Company (I refer to this in my testimony as “Non-standard Rebates”).⁴⁰

371 **Q. Does AIC intend to seek Commission approval for such Non-standard Rebates?**

372 A. No. AIC states, “The Company does not intend to seek Commission approval for any such
373 rebate, as it does not believe Commission approval to be necessary where a mutual
374 agreement is able to be reached between the Company and the Customer.”⁴¹

375 **Q. What do you conclude?**

376 A. I agree with JNGO witness Kenworthy who stated, “I am concerned that Ameren’s
377 methodology – which proposes to assign different rebate values for each of the several
378 thousand distribution transformers across its service territory – would be unreasonably
379 complex, opaque, and challenging for customers to understand.”⁴² I am also concerned that
380 the Company does not intend to establish a transparent process for the Commission, Staff,
381 and stakeholders to review and the Commission to approve future standard rebate and Non-
382 standard Rebate calculations. As in other tariff or ratemaking proceedings, parties should

³⁹ Ameren Exhibit 2.0, lines 480-483.

⁴⁰ *Id.*, lines 494-495.

⁴¹ JNGO Exhibit 3.03, AIC response to ELPC-VS 7.18(c).

⁴² JNGO Exhibit 1.0, lines 42:10-13.

383 have the opportunity to review and understand the inputs to the calculations, as well as the
384 results of the calculations.

385 Given the limited calculations and examples provided by Ameren, not knowing the
386 resulting short-term locational values, and the lack of transparency into future calculations,
387 it is premature for the Commission to approve the Framework.

388 **Q. What do you recommend?**

389 A. I recommend that the Commission:

390 1) Require AIC to calculate and publish all short-term locational value adders resulting
391 from its proposed Framework for all of AIC's customers, prior to Commission
392 approval of the methodology.

393 2) Require AIC to establish a transparent process for ongoing Commission, Staff, and
394 stakeholder review and Commission approval of the data and calculations supporting
395 the Framework's short-term locational value adders and Non-standard Rebates. This
396 should preferably be part of the robust and transparent Integrated Distribution
397 Planning process recommended by JNGO witnesses Kenworthy and Sandoval.

398 **IV. AIC'S PROPOSED FRAMEWORK IS FLAWED**

399 **Q. Do you consider AIC's proposed Framework to be conceptually correct?**

400 A. No. Specifically, I believe the Company's proposed DG Value Matrix is flawed, as it
401 incorporates both normal and emergency equipment ratings. Given the way AIC plans and
402 operates its distribution system, I believe only the normal rating of equipment, not the
403 emergency rating, is relevant for determining distribution capacity deferral value. I also

404 believe that Ameren's proposed approach ignores additional value from DG reducing
405 equipment loading below its normal rating.

406 **Q. Please explain once again what the DG Value Matrix is.**

407 A. AIC's proposed DG Value Matrix, shown in Figure 2 above, combines DG's contribution
408 to reducing equipment overloads with the equipment's upgrade/replacement cost to
409 determine the prorated distribution capacity value component of the short-term locational
410 value adder.

411 **Q. Do you agree with AIC's approach to the DG Value Matrix?**

412 A. No. As I previously explained, AIC proposes to use an asset's normal and emergency rating
413 as the lower and upper bound for determining its prorated capacity deferral value. I believe
414 only the normal rating of an asset, not the emergency rating, is relevant for determining
415 distribution capacity deferral value. The normal rating is what triggers investment
416 decisions for AIC, not the emergency rating. As the Company explains, "The normal rating
417 for a component generally represents the highest degree of loading that can be sustained
418 indefinitely without any appreciable reduction in the expected useful life of the asset. It is
419 also the point where, when the forecast loading on a component exceeds the normal rating,
420 a mitigation project is identified and appropriately added to future year investment plans."⁴³

421 **Q. What is the Company's rationale for including the emergency rating in determining
422 distribution capacity deferral value?**

423 A. AIC explains, "The emergency rating is representative of the point at which substantial
424 loss of equipment life, up to and potentially including the failure of the equipment, will

⁴³ Ameren Exhibit 2.0 lines 204-207.

425 occur. If the emergency rating were to be exceeded in the present year, absent the ability
426 to upgrade equipment in time to accommodate the loading, the critical goal of a mitigation
427 measure would be the reduction of the loading to at least below the emergency rating, and
428 ideally below the normal rating, in order to preserve the integrity of the equipment and
429 prevent any capacity related outage to customers.”⁴⁴

430 **Q. Do you agree?**

431 A. No. AIC takes action to replace an asset when loading is forecasted to exceed its normal
432 rating, not its emergency rating. As the Company explains, “Ameren Illinois does not plan
433 to operate assets above their normal rating when the system is in its normal configuration
434 ... For normal, non-contingency configuration overloads, Ameren Illinois typically
435 replaces assets that are forecasted to be over their normal rating within the window of time
436 that would be necessary to plan and execute the replacement project.”⁴⁵

437 **Q. As shown in Figure 2, three of the six cases in AIC’s proposed DG Value Matrix**
438 **involve the emergency rating. Should they be included?**

439 A. No, because these cases do not exist. In response to a data request, the Company admits,
440 “Ameren Illinois does not have any known locations where examples of Case 3, Case 5,
441 and Case 6 occur.”⁴⁶ AIC further explains, “In practice, it is unlikely that most components
442 will reach a point where the loading is forecasted to exceed the emergency rating, as
443 distribution capacity investments are typically placed in-service before any normal ratings
444 are actually exceeded in the present year.”⁴⁷ By including cases that relate to irrelevant

⁴⁴ JNGO Exhibit 3.03, AIC response to ELPC-VS 4.07(b).

⁴⁵ JNGO Exhibit 3.03, AIC response to POL 1.10.

⁴⁶ JNGO Exhibit 3.03, AIC response to ELPC-VS 4.07(a)

⁴⁷ Ameren Exhibit 2.0, lines 240-243.

445 asset emergency ratings in the DG Value Matrix, AIC distorts the distribution capacity
446 deferral value of DG.

447 **Q. Do you have additional concerns with AIC’s proposed DG Value Matrix?**

448 A. Yes. Ameren’s proposed proration approach ignores additional value from DG reducing
449 asset loading below its normal rating.

450 **Q. Please explain further.**

451 A. Consider a hypothetical scenario of an asset with a normal rating of 600 amps, emergency
452 rating of 660 amps, “Before DG” load of 610 amps, and “After DG” load of 580 amps. In
453 this scenario, the DG has eliminated 100% of the overload plus an additional 20 amps of
454 load relief, yet according to the proposed DG Value Matrix, AIC would only offer 17%⁴⁸
455 of the upgrade cost as a rebate.⁴⁹ In other words, AIC’s approach credits DG for deferring
456 only a small fraction of a projected asset replacement cost, even when in reality, the DG
457 has deferred the full cost of the asset replacement. This approach understates the short-term
458 locational capacity deferral value that DG provides.

459 **Q. What do you recommend?**

460 A. The DG Value Matrix should exclude cases involving asset emergency ratings, since AIC
461 acknowledges these cases do not exist. It should also fully reflect the value of DG reducing
462 asset loading below its normal rating. I recommend that the Commission require AIC to
463 modify its Framework to reflect the revised DG Value Matrix shown in Figure 5 below.

⁴⁸ $[(610-600)/(660-600)] = 17\%$.

⁴⁹ JNGO Exhibit 3.03, AIC response to ELPC-VS 4.07(c).

		Under Normal	Over Normal	Over Emergency	Value/Description	Value/Multiplier
Case 1	Before DG	X		NA	No Overload	No Value
	After DG	X		NA		
Case 2	Before DG		X	NA	Eliminated Overload	Full Upgrade Value
	After DG	X		NA		
Case 3	Before DG		X	NA	Reduced Overload	$\frac{(\text{Before Load} - \text{After Load})}{(\text{Before Load} - \text{Normal Rate})}$
	After DG		X	NA		
						$\frac{\text{Rebate Value} + \text{Upgrade Cost}}{\text{Value Multiplier}}$

464
465

Figure 5 – Revised DG Value Matrix

466 **Q. Please provide an illustrative example of how this revised DG Value Matrix would**
 467 **impact short-term locational value adders.**

468 **A.** Applying the revised DG Value Matrix to the Operationalized Example would increase the
 469 short-term locational value adder from \$25.99/kW (which AIC would round up to \$50/kW)
 470 to \$138.05/kW (which AIC would round up to \$150/kW) as shown in Figure 6 below.

Transformer Overload DER Value Example					
	2022	2023	2024	2025	2025
TC Peak Load	9.02	9.12	9.222	9.32	9.32
Normal Rating (MVA)	9	9	9	9	9
Emergency Rating (MVA)	10.7	10.7	10.7	10.7	NA
10% DR Nameplate PV MW	4.2	4.3	4.3	4.4	4.4
10% DR Peak Load Reduction (MW)	0.941	0.943	0.963	0.979	0.979
Replacement Cost	\$780,300	\$795,906	\$811,824	\$828,061	\$828,061
Available Rebate Value (\$)	\$9,180.00	\$56,181.60	\$106,014.68	\$155,870.23	\$828,061
Rebate Value (\$/kW)	\$2.19	\$13.07	\$24.65	\$35.43	\$188.20
Present Year Rebate Value (\$/kW)	\$1.93	\$10.85	\$19.24	\$25.99	\$138.05

471
472

Figure 6 – Revised Operationalized Example

473 **V. AIC'S PROPOSED FRAMEWORK IS TOO NARROWLY FOCUSED**

474 **Q. Do you consider AIC's proposed Framework to be sufficiently complete?**

475 A. No. I agree with JNGO witness Kenworthy who stated, "A proposal that only values the
476 short-term, locational value of solar PV is incomplete. It ignores much of the value that
477 DER can provide to the distribution grid"⁵⁰

478 **Q. Do other parties in this proceeding also agree?**

479 A. Yes. JNGO witness Sandoval explains the range of values from DER⁵¹, and Joint Solar
480 Parties ("JSP") witness Rábago describes the DER value components identified by other
481 utilities.⁵² The Company also initially identified the need to develop a valuation framework
482 for the wide range of services available from different types of DER.

483 **Q. How broad did AIC initially intend its Framework to be?**

484 A. It appears that, early on, AIC intended to develop a broad framework that accounts for
485 different types of DER. The October 2018 PNNL white paper summarizing the workshops
486 and comments from Staff's DG valuation stakeholder engagement process states, "The
487 differences between this proposed (Ameren) approach and the Minnesota example ...
488 include that Minnesota's process only applies to solar, whereas Ameren's is intended to be
489 more widely applied to different types of DERs."⁵³

⁵⁰ JNGO Exhibit 1.0, lines 41:9-10.

⁵¹ JNGO Exhibit 2.0, pp. 20-25.

⁵² JSP Exhibit 1.0, Table KRR-2, p. 31.

⁵³ Ameren Exhibit 1.1, p. 35 of 61.

490 **Q. What DER types did the AIC team originally consider in developing the Framework?**

491 A. Ameren’s internal Team Summary document shows a wide variety of DER types and
492 services, including distributed generation (solar PV, gas-fired Sterling engines), combined
493 heat and power, energy storage, demand response, and smart EV charging.⁵⁴ The document
494 states, “... the team needs to assess the different services each DER technology can
495 support, and provide a valuation framework for it.”⁵⁵

496 **1. The Framework should consider the impact of other DER, particularly solar-**
497 **plus-storage, on the value of DG**

498 **Q. Does AIC’s proposed Framework include all DER technologies?**

499 A. No. AIC’s proposed Framework includes only DG (primarily solar)⁵⁶, which AIC describes
500 as the “immediate need”.⁵⁷ The Company explicitly excluded storage from the Framework
501 because, according to its interpretation of Illinois law, batteries or other forms of storage
502 are not "distributed generation".⁵⁸

503 **Q. Do you agree with this approach?**

504 A. No. Ameren’s pivot from considering a wide variety of DER types to focusing only on
505 solar DG unfortunately risks establishing a valuation Framework that is inflexible and
506 incapable of reflecting the full impact of various DER combinations on the value of DG.
507 In particular, the valuation Framework should account for the impact of solar paired with
508 energy storage (“hybrid systems”) on the value of DG.

⁵⁴ JNGO Exhibit 3.03, AIC response to ELPC-VS 5.01 Attach 5, Table 2, p. 4.

⁵⁵ JNGO Exhibit 3.03, AIC response to ELPC-VS 5.01 Attach 5, p. 4.

⁵⁶ Ameren Exhibit 1.0, lines 591-597.

⁵⁷ JNGO Exhibit 3.03, AIC response to ELPC-VS 5.01 Attach 5, p. 1.

⁵⁸ Ameren Exhibit 1.0, lines 598-601.

509 **Q. Why is it important to reflect the impact of storage in the Framework?**

510 A. As JNGO witness Kenworthy explains, “While distributed generation can provide ...
511 benefits on its own, those benefits are enhanced when the distributed generation is coupled
512 with energy storage. For example, while rooftop solar on its own has a very predictable
513 generation profile over a long period, on any given day it may have more or less availability
514 depending on the sun. However, when paired with storage, the likelihood of the systems’
515 ability to provide generation or other services at times of highest demand increases
516 dramatically. As such, its value as a distribution system asset is enhanced.”⁵⁹

517 **Q. Has any jurisdiction quantified the enhanced value of solar-plus-storage?**

518 A. Yes. In Connecticut, a 2020 draft value of DER study found that the 25-year levelized
519 value of solar DG is \$0.141 per kWh and the value of solar DG paired with storage is
520 \$0.228 per kWh, a 62% increase in value.⁶⁰

521 **Q. Are customers increasingly purchasing hybrid systems?**

522 A. Yes. Due to declining costs and the reliability/resilience benefits of energy storage,
523 customers are increasingly choosing to pair their solar installation with batteries. In their
524 most recent U.S. Solar Market Insight report, SEIA and Wood Mackenzie state that, by
525 2025, one-fifth of new utility PV systems, one-third of new residential solar systems, and
526 one-quarter of new non-residential solar systems will be paired with energy storage.⁶¹

⁵⁹ JNGO Exhibit 1.0, lines 28:4-10.

⁶⁰ *Value of Distributed Energy Resources in Connecticut*, CT Department of Energy and Environmental Protection, CT Public Utilities Regulatory Authority, at 10, Figure 1, July, 2020, [http://www.dpuc.state.ct.us/dockcurr.nsf/8e6fc37a54110e3e852576190052b64d/56d151da9f6343af852585980063329d/\\$FILE/Value%20of%20DERs%20in%20Connecticut%20-%20Draft%20Study.pdf](http://www.dpuc.state.ct.us/dockcurr.nsf/8e6fc37a54110e3e852576190052b64d/56d151da9f6343af852585980063329d/$FILE/Value%20of%20DERs%20in%20Connecticut%20-%20Draft%20Study.pdf).

⁶¹ Wood Mackenzie/SEIA U.S. Solar Market Insight®, September 2020, p. 5.

527 Sunrun’s CEO Lynn Jurich recently stated that the company is laying the groundwork for
528 “what we believe will be a market where in two or three years every solar system has a
529 battery.”⁶²

530 **Q. What are the implications of this growth in hybrid systems?**

531 A. AIC and other utilities will have a significant opportunity to take advantage of these
532 customer-financed resources to benefit its grid and thereby reduce costs for all customers.
533 In doing so, it is important that AIC compensate its DER customers fairly.

534 **Q. What are some examples of utilities compensating customers for the use of their
535 storage or hybrid systems?**

536 A. Green Mountain Power (“GMP”) in Vermont has a bring-your-own-device program
537 offering incentives in exchange for control of customer-owned batteries during peak
538 periods. GMP’s incentive is \$850/kW for a three-hour discharge and \$950/kW for a four-
539 hour discharge. Batteries in areas of the state where load relief is needed most can get an
540 extra payment of \$100/kW enrolled.⁶³

541 Another example is National Grid’s ConnectedSolutions bring-your-own-battery program
542 in Massachusetts and Rhode Island. Customers enroll their hybrid systems in the program
543 and allow the utility to discharge the batteries during 30-60 peak events each year. Unlike
544 the one-time upfront incentives offered by GMP, National Grid offers annual pay-for-

⁶² Comments from Sunrun CEO Lynn Jurich during the Q3 2020 Earnings Call on November 5, 2020. Transcript available at <https://seekingalpha.com/article/4385636-sunrun-inc-run-ceo-lynn-jurich-on-q3-2020-results-earnings-call-transcript>.

⁶³ Green Mountain Power. Bring Your Own Device. Available at: <https://greenmountainpower.com/rebates-programs/home-energy-storage/bring-your-own-device/>.

545 performance incentives based on the average available capacity of the customer-owned
546 batteries during peak events. The annual incentive is \$225/kW in Massachusetts⁶⁴ and
547 \$400/kW in Rhode Island.⁶⁵

548 **Q. What would be the impact if AIC were to account for hybrid systems in its**
549 **Framework?**

550 A. I believe that appropriately accounting for hybrid systems would require AIC to
551 fundamentally change its Framework methodology. Hybrid systems have a different
552 operating profile than stand-alone solar. A solar-plus-storage system's output is not limited
553 to hours of the day when the sun is shining. With the right incentives, customers with solar-
554 plus-storage will charge their batteries during the day, then discharge their batteries to serve
555 their own and adjacent customers' load at times of circuit peaks whenever they may occur.
556 Operating in this way, solar-plus-storage upends the concept of diminishing returns, which
557 as I explained earlier in my testimony, is one of the key concepts underpinning AIC's
558 proposed Framework. Incremental additions of hybrid systems do not result in declining
559 contributions to circuit peak loads.

⁶⁴ National Grid. Battery Program. Available at: <https://www.nationalgridus.com/MA-Home/Connected-Solutions/BatteryProgram>.

⁶⁵ National Grid. Use Your Battery Storage Device to Make the Grid More Sustainable. Available at: <https://www.nationalgridus.com/RI-Home/ConnectedSolutions/BatteryProgram>.

560 **Q. Does AIC acknowledge the impact of hybrid systems on the concept of diminishing**
561 **returns?**

562 A. Yes. In response to a data request, AIC states “PV paired with storage would have a
563 different operating profile than solar alone and therefore would change the impact of
564 diminishing returns.”⁶⁶

565 **Q. Why has AIC not included the impact of hybrid systems in its Framework?**

566 A. As I explained previously, AIC disregards storage because, under the Company’s
567 interpretation of Illinois law, storage technologies are not distributed generation.

568 **Q. Does AIC consider hybrid systems to be distributed generation?**

569 A. In response to a data request, Ameren responded: “The Company considers the solar PV to
570 be ‘distributed generation’ as defined by the statute, but does not understand the storage
571 components that augment the output profiles of distributed generation to qualify as
572 ‘distributed generation’ as defined by the statute. Storage can provide benefits to customers
573 with DG but AIC does not understand the statute to permit it to be included in the DG
574 rebate calculations.”⁶⁷

575 In other words, AIC acknowledges that storage modifies the output profiles of solar DG
576 and provides incremental value, but does not feel it can reflect that reality in its proposed
577 DG rebate. I am not a lawyer and cannot offer a legal interpretation of the statute, but I
578 believe any framework for determining DG rebates should account for the unique impacts
579 of storage on the operating characteristics and value of solar DG.

⁶⁶ JNGO Exhibit 3.03, AIC response to ELPC-VS 4.06(a).

⁶⁷ JNGO Exhibit 3.03, AIC response to ELPC-VS 7.08(e).

580 **Q. Has AIC attempted to model the potential impact of hybrid systems on the concept of**
581 **diminishing returns in its Framework?**

582 A. No. The Company states, “Within a specific feeder, the impact of storage is highly
583 dependent on the power rating, energy rating, operating profile, and system configuration.
584 In addition, its behavior cannot be easily generalized (as is possible with solar or wind DER
585 operating with a smart inverter meeting Ameren Illinois specifications), since customers
586 on a specific feeder could operate their storage in a variety of different ways without direct
587 utility control. Therefore, it would be speculative to determine how storage paired with PV
588 could impact the diminishing returns of incremental PV additions.”⁶⁸

589 **Q. Should AIC account for other DER in its proposed Framework?**

590 A. Yes. Load-modifying DER, such as controllable thermostats and water heaters, could affect
591 the dispatch parameters of a storage resource in the same home or building, thereby
592 impacting the value of a hybrid system.⁶⁹ While today’s Illinois DER market is still
593 maturing, it is likely that customers will deploy future DER in increasingly creative
594 combinations to provide optimal distribution grid value. With that future state in mind, AIC
595 should establish a Framework that is flexible and can reflect the impacts of various DER
596 on solar DG paired with storage.

597 **Q. What do you conclude?**

598 A. AIC’s failure to account for the impacts of hybrid systems on the value of solar DG, as
599 well as its failure to account for the impacts of any other types of load-modifying DER, is

⁶⁸ JNGO Exhibit 3.03, AIC response to ELPC-VS 4.06(a).

⁶⁹ NESP, *National Standard Practice Manual for Benefit-Cost Analysis of Distributed Energy Resources*, National Energy Screening Project, p. 11-12, August, 2020, https://www.nationalenergyscreeningproject.org/wp-content/uploads/2020/08/NSPM-DERs_08-24-2020.pdf.

600 a significant deficiency in its proposed Framework. I completely agree with Staff witness
601 Clausen who states, “the different output profile of DG projects that are connected to
602 storage should be accounted for in the calculation of the DG rebate values.”⁷⁰

603 **2. DG rebates should include additional long-term, system-wide DER value**

604 **Q. What values should AIC include in the full DG rebate?**

605 A. The full DG rebate value should include value components derived from a comprehensive
606 Value of DER analysis. JNGO witness Sandoval explains that a comprehensive Value of
607 DER analysis includes a quantification of long- and short-run avoided capacity costs,
608 avoided line losses, reliability/resilience benefits, and voltage support services⁷¹ over the
609 lifetime of the DER.⁷² Mr. Sandoval⁷³ and JSP witness Rábago⁷⁴ provide summaries of the
610 value components included in Value of DER studies conducted by other utilities.

611 **Q. Does AIC’s Framework reflect DER value over its lifetime?**

612 A. No. The Company’s Framework only considers the short-term locational value
613 contribution from DG over AIC’s 5-year distribution planning horizon and ignores value
614 beyond that point in time. Solar panels have a typical useful life of at least 25 years.⁷⁵ I
615 agree with Staff witness Clausen who states, “I am skeptical ... that the value of a DG
616 resource drops to zero in years six and beyond for every single project.”⁷⁶

⁷⁰ ICC Staff Exhibit 1.0, lines 162-163.

⁷¹ JNGO Exhibit 2.0, pp. 20-25.

⁷² *Id.*, line 19:10.

⁷³ *Id.*, Figure 1, p. 16.

⁷⁴ JSP Exhibit 1.0, Table KRR-2, p. 31.

⁷⁵ Solar Reviews. “How long do solar panels actually last?” Available at: <https://www.solarreviews.com/blog/how-long-do-solar-panels-last>.

⁷⁶ ICC Staff Exhibit 1.0, lines 99-101.

617 **Q. Does AIC’s Framework reflect system-wide DER value?**

618 A. No. JNGO witness Sandoval explains that DER provide “unspecified” value across the
619 distribution system regardless of its location.⁷⁷ AIC’s failure to include this system-wide
620 DER value is another deficiency in its proposed Framework.

621 **Q. What do you recommend?**

622 A. I recommend that the Commission:

- 623 1) Determine that AIC’s proposed Framework is incomplete and produces only short-
624 term locational value adders, not rebate values reflecting the full value of DER to the
625 distribution system.
- 626 2) Require AIC to modify its proposed Framework for determining short-term
627 locational value adders to include the impact of solar paired with storage and other
628 load-modifying DER.
- 629 3) Order AIC to begin working with Staff, stakeholders, and an independent 3rd party
630 facilitator, to conduct a comprehensive and transparent Value of DER analysis to
631 determine the full DG base rebate value.

632 **Q. Is conducting a comprehensive and transparent Value of DER analysis a lengthy**
633 **process?**

634 A. Based on what I’ve seen in other states, the analysis could take a while. Given the transition
635 to value-based compensation once AIC reaches a 5% DG penetration, it is important to be
636 prepared to establish an initial base rebate value regardless of the status of the analysis. If
637 the Company has not completed the Value of DER analysis before reaching 5% penetration

⁷⁷ JNGO Exhibit 2.0, lines 10:8-11:2 .

638 in its service territory, I recommend that the Commission require AIC to establish an initial
639 base rebate value equivalent to the value of delivery-service netting, as recommended and
640 further detailed in JNGO witness Kenworthy's testimony.

641 **VI. SUMMARY OF RECOMMENDATIONS**

642 **Q. Please summarize your recommendations.**

643 A. I recommend that the Commission:

644 1) Determine that AIC's proposed Framework is incomplete and produces only short-
645 term locational value adders, not rebate values reflecting the full value of DER to the
646 distribution system.

647 2) Require AIC to modify its proposed Framework for determining short-term
648 locational value adders to:

- 649 a. Include the impact on the value of DG when it is paired with storage.
650 b. Build flexibility into the Framework that allows AIC to reflect, in rebate values,
651 the impact of other load-modifying DER on the value of solar DG paired with
652 storage, as those impacts are better understood and quantified in the future.
653 c. Incorporate the revised DG Value Matrix shown in Figure 5.

654 3) Require AIC to calculate and publish all short-term locational value adders resulting
655 from its proposed Framework for all of AIC's customers, prior to Commission
656 approval of the methodology.

657 4) Require AIC to establish a transparent process for ongoing Commission, Staff, and
658 stakeholder review and Commission approval of the data and calculations supporting
659 the Framework's short-term locational value adders and Non-standard Rebates. This

660 should preferably be part of the robust and transparent Integrated Distribution
661 Planning process recommended by JNGO witnesses Kenworthy and Sandoval.

662 5) Order AIC to begin working with Staff, stakeholders, and an independent 3rd party
663 facilitator to conduct a comprehensive and transparent Value of DER analysis to
664 determine the full DG base rebate value.

665 6) To the extent the Company has not completed the Value of DER analysis before DG
666 penetration reaches 5% in AIC's service territory, order AIC to establish an initial
667 base rebate value equivalent to the value of delivery-service netting, as
668 recommended and further detailed in JNGO witness Kenworthy's testimony.

669 **Q. Does this conclude your testimony?**

670 A. Yes.